

- (v) Hazardous wastes (management and handling) Rules, 1989 and Amended Rules, 2000
- (vi) Manufacture, Storage and Import of Hazardous Chemicals Rules, 1989 and Amended Rules, 2000
- (vii) Manufacture, Use, Import and Storage and Hazardous Micro-Organisms, Genetically Engineered Organisms or Cell Rules, 1989
- (viii) The Public Liability Insurance Act, 1991 and Amended Act, 1992
- (ix) The Public Liability Insurance Rules, 1991 and Amended Rules 1993
- (x) Biomedical Wastes (Management & Handling) Rules, 1998 and Amended Rules 2000 if applicable.
- (xi) Recycled Plastics Manufacture and Usage Rules 1999, if applicable and
- (xii) Ozone Depleting Substances (Regulation & Control) Rules, 2000, if applicable
8. You will have to abide by any other stipulations as may be prescribed by any authority/local bodies/Government Departments etc.

SPECIAL CONDITION :

Enclosed in Annexure.

Total Capital investment on land, building, plant and machinery including capital investment on pollution control system is Rs. 5829.95 lacs only.

Any violation of the aforesaid conditions shall entail cancellation of this Consent to Establish (NOC)

Yours faithfully,

[Signature]
 Member Secretary,
 West Bengal Pollution Control Board

Dated

Memo No.

Copy forwarded for information to :

- Chief Inspector of Factories, Government of West Bengal, N. S. Building, Kolkata-700 001
- Director of Industries/Director of Cottage & Small Scale Industries, Government of West Bengal. N. S. Building, Kolkata-700 001
- Guard file, West Bengal Pollution Control Board.
- Environmental Engineer, VIII/Alipur R.O./Howrah R.O./Hooghly R.O./B.R.O./D.R.O./Haldia R.O./S.R.O./Malda R.O./Asansol Sub-R.O./WBPC Board

Himalaya Bhawan
 Delhi Road, Dankuni
 Dist. Hooghly

Vill, Panpur
 Kalyani Expressway
 P.O. Narayanpur
 Dist. 24 Pgs. (N)

Sahid Khudiram Sarani
 City Centre, Durgapur-16
 Dist. Burdwan

7, Haradeb Bhattacharjee
 Lane, P.S.-Shibpur
 Howrah-711102

Paribesh Bhawan
 10A, LA-Block, Sector-III
 Bidhannagar
 Kolkata-700 098

Block-05 at 40
 Flats Complex
 Adjacent to Priyambada
 Housing Estate
 P.O. : Khanjanchak,
 P.S. Durgachak
 Haldia-721602
 Dist. : Purba Medinipur

Paribahan Nagar
 Matigara, Siliguri
 Dist-Darjeeling

10, Camac Street
 2nd Floor
 Kolkata-700 017

should comply with the emission standard of P.M. - 100 mg/Nm³.

Stack to have sampling port, platform and ladder as per the Emission Regulation part -III of CPCB.

B) Effluent :-

- 1) Process – after proper treatment in ETP in conformity with Environmental Standard for discharge of effluent.
- 2) Domestic – to be discharged after proper treatment.

C) Solid Waste :-

- 1) Ash – to be utilized/ disposed off as per MoEF Guidelines.

D) General :-

- 1) Noise Control – Ambient noise level not to exceed the permissible limit. Every care to be taken for noise control.
- 2) No additional machinery/ equipments can be installed without prior permission from the State Board.
- 3) The unit should obtain “Consent to Operate” from the State Board before commissioning the modernization/ renovation project.
- 4) Proper dust extraction and dust suppression system to be adopted to control fugitive emission.
- 5) The unit must ensure dry ash collection in silo and use of pneumatic system for dry ash transfer.
- 6) Dry collection of fly ash and ash utilization to be followed as per MoEF Notification dated : 14/09/1999 and subsequent amendments.
- 7) Proper fire detection and protection system to be provided to control fire and explosion hazards.
- 8) Provision of personal protective equipments like ear plug, ear muffs etc. to be made to ensure occupational health and safety of workers.
- 9) Afforestation and green belt development programmes to be adopted.
- 10) The unit should explore the possibility of zero discharge as proposed.
- 11) This NOC is valid upto **31/08/2016** for setting up CPP 12 MW, at the existing premises.



29/11/11

Dr. Somnath Narayan
Senior Environmental Engineer
West Bengal Pollution Control Board
Somnath Narayan
Senior Environmental Engineer
Kankinara Circle Office
W.B., Pollution Control Board